

Aqualab
1188 Suncook Valley Highway
Epsom, NH 03234

Telephone (603) 798-3311
Fax (603) 798-3316

Certificate of Analysis

Granite State Home Insp.

Collected By: Rich Burns

Client: Peggy Green

Site: 98 Mountainside Drive
Newbury, NH

Sampled: 6/16/00, 11:15 a.m.

Analyzed: 6/17/00, 11:10 a.m.


Parameter	Level	EPA/STATE LIMIT
Total Coliform/100mL	Absent	Absent (zero)
E. coli/100mL	Absent	Absent (zero)
Color	0 CU's	15 CU's
Turbidity	0.2 NTU	1 NTU
pH	7.37	6.5 - 8.5
Hardness	60 mg/L	NL (soft)
Chloride	17 mg/L	250 mg/L
Fluoride	0.23 mg/L	4.0 mg/L
Iron	0.05 mg/L	0.3 mg/L
Manganese	0.004 mg/L	0.05 mg/L
Nitrate (as N)	0.20 mg/L	10 mg/L
Nitrite (as N)	0, BDL	1.0 mg/L
Sodium	11 mg/L	250 mg/L

NL = No Limit

BDL = Below Detection Limit

COMMENT: All primary and secondary analytes tested above are within both State and EPA recommended limits for safe drinking water.

APPROVED:



NEW ENGLAND RADON, LTD.

50 Northwestern Drive, Unit 11
Salem, New Hampshire 03079

603-893-4260
Fax: 603-893-8163
E-Mail: ner@tiac.net

RADON IN WATER ANALYSIS RESULTS

DATE: 06/20/2000

MS PEGGY GREEN
97 LOCKWOOD RD
ANDOVER, NH 03216

VIAL #: 14938

GSHI

TEST SITE: 98 MOUNTAINSIDE DR, NEWBURY, NH

SAMPLE NO.: 14938

RESULTS: 919 pCi/L

FOR WATERBORNE RADON (I.E., RADON IN WELL WATER), NO STANDARD AS RECEIVED A CONCENSUS, PARTLY BECAUSE THE HEALTH IMPACTS ARE LARGELY INDIRECT AND DEPEND UPON VARYING FACTORS (SUCH AS VENTILATION AND WATER USE HABITS). SOME STATES HAVE SET GUIDELINES FOR FOLLOW-UP ACTION. IN NEW ENGLAND THEY ARE AS FOLLOWS: NEW HAMPSHIRE (2000 pci/L), MASSACHUSETTS (10,000 pci/L), MAINE (20,000 pci/L) AND VERMONT (10,000 pci/L).

FOR ADDITIONAL INFORMATION ON RADON IN WATER, YOU MAY CONTACT YOUR STATE RADON OFFICE.

CT 203-566-3122

MA 413-596-7525

ME 207-287-5743

NH 603-271-4674

RI 401-277-2438

VT 802-865-7730.

(THIS READING IS VALID ONLY IF SAMPLE HAS BEEN TAKEN AS INDICATED IN THE INSTRUCTIONS. NEW ENGLAND RADON, LTD. CANNOT BE HELD LIABLE FOR ERRONEOUS RESULTS IF THE SAMPLE IS NOT TAKEN ACCORDING TO THE INSTRUCTIONS.)

ROBERT LUCAS & SON
ARTESIAN WELL DRILLING COMPANY
P.O. Box 221, Newport, NH 03773
(603) 863-4437

May 6, 2003

att: George Sanders

Carl Olson
Mt Side Rd.
Newbury, NH 03255

Drilled 6" 270' deep

Bedrock 60'

Pipe set at 70'

Well producing 5 gal. per min.

Static 10'

Well was drilled in 1988

Robert Lucas